SECTION 37

SPECIAL REQUIREMENTS FOR LABORATORIES

Table of Contents

37.0 SPECIAL REQUIREMENTS FOR LABORATORIES 2
37.1 Design Issues 2
37.2 The Laboratory Design Brief – the Generic Laboratory 3
37.3 Laboratory Design 4
37.4 Laboratory Furniture 7
37.5 Special Laboratory Equipment 9
37.6 Finishes 12
37.7 Hydraulics 13
37.8 Air-Conditioning and Ventilation 14
37.9 Lighting and Power 15
37.10 Communications, Data and Security 15
37.11 Audio Visual 16
37.12 Fume Exhaust Systems 16
37.13 Gas Reticulation: 16
37.14 Health & Safety Provisions 17
37.15 Access to Laboratories for People with Disabilities 17
37.16 Special Hazard Laboratories 18

Version	Date	Authors	Summary of Changes
Draft 01	11/07/2013	SKM for JCU	
Draft 02	21/08/2013	SKM for JCU	Estate Office comments incorporated
AV Draft 1	3/6/2014	Derek Powell	AV Specific Section added
3	19/8/14	GM	Issued to web

37.0 SPECIAL REQUIREMENTS FOR LABORATORIES

37.1 Design Issues

37.1.1 Laboratory Definition

This section deals with the spaces used for research or teaching activities with a technical or scientific function, in which there is a potential risk or hazard to users are described as 'Laboratories'. Non-hazardous spaces often called 'Dry Laboratories', which may include computer facilities and language laboratories are not covered in this section.

Laboratories may be required in areas such as Biosciences, Medical Research, Physics, or Chemistry and may include teaching, research, quality control, testing or analysis. These activities may require the usage of chemicals, including dangerous goods, hazardous substances, electrical or radiation hazards, pathogens, quarantine materials or work processes which could also be hazardous.

Special Hazard Laboratories are areas within laboratories (or whole laboratories) in which particularly hazardous substances are used or specific hazardous processes are required which necessitate the requirement to conform with specific standards and legislation in their design and operation. The standards relating to these special hazard laboratories will over and above the regulatory requirements which are listed in the following section. These special hazard laboratories may include microbiological laboratories, vivariums, cytotoxic chemical preparation rooms, clean rooms and radiological laboratories to cite examples

The designated laboratory areas should include, or have access to, all support spaces required, such as, instrument and preparation labs, laboratory stores, sample stores, chemical stores, wash up, media prep, sterilization facilities, waste storage and waste treatment facilities. Administration and office accommodations should not be within the laboratory boundary Tc -0<5-0.7J 0 Tc 0n

Estate Office

37.2.1.11

grid and have minimum impact on flexibility of floor layout and future services penetrations.

37.3.1.2 A lab planning grid of 3.3m allows flexibility in bench depth and maintains equity and lab code access requirements. Laboratory modules may be 33m² (10 x 3.3m) or 40m² (12 x 3.3m) with laboratory support modules of 24m² (7.2 x 3.3m) and should be used wherever possible to facilitate efficien

environments need to adjust to allow for smaller work group models, formalised practical classes and other events and displays.

Changing teaching methodology has affected the layout and design of tertiary teaching laboratories which need to be adaptable

37.3.4 Risk Assessment

Carry out a detailed risk assessment (analogous to HAZOP procedures) using the design brief. This should engage all key stakeholders and must be completed in order to record recognised risks and responses in accordance with the Queensland Work Health and Safety Act and Regulations requirements.

37.3.5 Hazardous Zone Assessment

An accredited auditor shall be provided (as part of the Principal Consultancy Service) to identify and zone any hazardous areas to ensure unsuitable electrical equipment is not used where there is potential for creating fire or explosion through ignition of flammable vapours and gases. Maximum allowable quantities and their storage locations are to be documented, and will be used to inform the continued safe operation of the laboratory. Scientific User Groups shall provide an inventory of all intended hazardous substances under the ChemWatch Gold system which maintains a hazardous substance register for compliance with the Queensland Fire and Rescue Service requirements.

37.3.6 Consultation

To ensure compliance with the design guidelines there shall be close collaboration and coordination between the consultants and the University's Estate Office. Close liaison with the University Workplace Health and Safety Coordinator is also required.

37.4 Laboratory Furniture

The needs of the particular laboratory activities should influence the design of the laboratory furniture whilst maintaining a flexible loose furniture layout in the general laboratories. Benching should be loose where possible, but may also need to be fixed in certain circumstances, and may

Bench top surface material selection shall take into account the anticipated laboratory activities, including risks of staining, scratching and burning and the texture / pattern of the material.

All bench tops should include an appropriate drip mould to University approval with integral front edges to be an extension of the surface top material, whether it be either of the material options stated below

Bench surface material options:

37.4.1.1 Cellulose fibre, homogeneously reinforced phenolic thermosetting resin core - Trespa Toplab Plus (typically 16mm)

37.4.1.2 “Chemical resistant” Laminate post formed over high moisture resistant (HMR) stru

This shelving should comprise

Estate Office

Balance benches may be required for measuring or microscopic work. Verify the type of vibration isolation required. Balance Benches may consist of fully welded steel framed rigid benching, terrazzo topped steel benching which should be included in the construction budget.

37.5.3 Equipment Typically in FF&E Budget

37.5.3.1 Furnace or Drying Oven
Provide heavy duty benching, non-combustible adjacent surfaces and sufficient power to suit these heavy, high temperature pieces of equipment. Special ventilation or exhaust may be necessary.

37.5.3.2 Microwave Ovens
Provide appropriate benching and power to suit the appliance. Individual ventilation or exhaust may be required. Locate to minimise explosion risk to operator and other laboratory staff / students.

37.5.3.3 Biosafety or Laminar Flow Cabinets for PC2 / PC3 Areas
Provision for Biosafety or laminar flow cabinets may be required. Ensure that sufficient space is maintained to accommodate these large appliances. Services required may include power, gases, water and drainage. Determine type & quality of each. To be installed in accordance with regulatory requirements.

37.5.3.4 Vibration Isolation / Balance Benches
Balance benches may be required for measuring or microscopic work. Verify type of vibration isolation required. Balance Benches may consist of proprietary airbag suspended furniture depending on requirements which would be from FF&E budget.

37.5.3.5 Custom made or proprietary chemical storage cabinets.
Cupboards for chemical storage may be custom made or special proprietary types with internal bunding, lockable closing doors and made of various materials (typically steel or polypropylene). Note that special code requirements apply to classification, and hazard type (flammability, toxicity, corrosive), segregation by classification, and quantity.
Note that the stated (theoretical) capacities of proprietary storage cabinets do not reflect the realistic / practical storage capacity when storage container sizes are taken into account.
Flammables cabinets should be non-vented type. Refer to Mechanical Services Section 20.3.62 Flammables Cabinets for detailed description.

37.5.3.6 Low Temperature Freezers
Installation of proprietary low temperature (typically -20, -50 or -80 deg C) freezers may be required. Check requirements for power (typically 5A or 20A) with potential essential power and/or CO2 backup systems, temperature alarms (both local and remote). Consider locating -80 deg C freezers in a dedicated room to enable efficiency of air conditioning.

37.6 Finishes

Code requirements shall be met with regard to selected finishes; Factors which may be applicable include slip resistance, ease of cleaning (smoothness, sealed joints, provision of coves, avoidance of construction joints), resistance to chemicals and / or cleaning / decontamination agents flammability. Impervious materials shall be used on walls, floors and benches.
In wet laboratories where there is the potential for water spills and flooding, the optimal flood containment and minimal risk of leakage to lower floors is required. Appropriate detailing and construction sequence of these spaces is vital.

37.6.1 Floors

Check requirement for anti-static conditions with welded joints.
Generally sheet vinyl is to be used in laboratories unless specifically required for other purpose (such as epoxy coated floors for hose down areas). Rubber flooring may also be considered if appropriate to the application.
Electrical exclusion zones, including at safety shower and eye wash locations, should be marked in contrasting colours on floor.

37.6.2 Walls

The primary purpose of this is to assess the chemical resistance to staining and damage of the proposed finishes against the specific chemicals that will be used in the particular spaces in question. While the proposed finishes should be selected for their known general high level of chemical resistance, particular chemicals can have different effects on otherwise seemingly similar finishes and colours.

For each finish type and colour, material samples form 4 sets of alternative suppliers should be distributed to the user groups of each building / laboratory. Provide plans showing allocation of finishes types to the various spaces, to assist in deciding which chemicals need to be tested on which finishes. The codes for each finish should also be marked on the matching samples for ease of identification. User groups should undertake testing along the following lines:

- Users should set up a grid on each of the samples, and record the chemicals on a matching grid drawn up on a sheet of paper.
- Testing for all chemicals for periods of time similar to how long a spill might be left for, but also up to 24 hours to simulate repeated staining over time.

37.7 Hydraulics

Refer Section 24 Hydraulic Services and Section 20 Mechanical Services for Special Laboratory Water Systems

Wet laboratories typically require laboratory process sinks and hand wash basins which are located near entry / exit points and are potentially dedicated to a particular activity. Provide both hot and cold water as required.

37.7.1 Laboratory Fixtures and Fittings

Laboratory sinks are typically fabricated from certified Grade 316 stainless steel and can either be single or double bowl sinks. These typically have integral drainers and splashbacks, minimum 300mm high and are either inset or pot sink type. Fabrication from other materials may be necessary, such as under bench mounted porcela wor usy3.3(b)-0/1VTj nfa724(av)pc

Eyewash and safety showers are to be provided in accordance with AS/NZS 4775. Their location should not constitute a slip hazard for users and they should not be located in the main exit from the laboratory.

Ensure selection of model is suitable also for use of people in wheelchairs i.e.safety shower spray covers diameter of wheelchair and control mechanism is accessible from wheelchair.

Eyewash stations shall be plumbed to waste.

37.7.3.1 Drainage Floor waste drains should be avoided within wet laboratories and the

The roof and/or ceiling space for each laboratory is to be tested for airtightness to enable complete pressure and humidity control of the space. Pay particular attention to the design of ceiling spaces below lightweight roof construction, to ensure adequate airtightness for both humidity control, and potential effect on the pressure control of internal spaces below.

37.8.1 Fume Cupboards

Refer to Mechanical Services Section 20.3.61
Provide the space necessary to accommodate these large appliances, to be installed in accordance with regulatory requirements, which should be fully integrated into the design of the laboratory fixtures and furniture. Services required would typically include power, gases, water, drainage. Determine type and quality required for each. Code requirements for space clearances to fume cupboards must be satisfied, consideration of location of fume cupboard in relation to access in the laboratory, adjacent walls and columns, other items of equipment.

Refer to 37.3.1 for requirements to provide exhaust and reticulated services to anticipated (future fume cupboard) locations.

Therequirements for fume scrubbing must be determined. Consideration of the visual impact,location and dimensions of exhaust flues in terms of their aerodynamic effectiveness taking account of prevailing wind directions, proximity to adjacent ventilation openings or windows, proximity to adjacent structures as causes of turbulence. In challenging locations or to fulfil EPA conditions, a comprehensive air flow / dispersion study may be required.

37.9 Lighting and Power

12.J 01()5.0 Tc[(Re)1.2(fe)-0.7(r)-2.5(e)1.4(Services Issue 52.7(T)-14.2(e)-3.7(c)-4.3(h)-4.3(n)-0.4(i)-5.6(c)-0.7(a)-2.7(l)-5.2(S)-0.7(p)-2.5(e)1.4(c)1.4(i)-5.6(f)-2.7(i)-5.6(c)-0.7(a)-2.7(t)-5.2(i)-5.6(o)-0.7(n)-2.7(s)]TJ 0.209 Tc 0 Tw (\(27\)5

another designated monitoring station. Liaise with stakeholders to determine requirements for monitoring of essential equipment such as fridges and freezers.

37.11 Audio Visual

Refer Section 27 AV Standards

Based on the pedagogy to be employed (in teaching laboratories) or the specific users' requirements (in research laboratories) determine the facilities needed for source equipment (including PCs and cameras), video display equipment and audio equipment (including hearing assistance).

Special provision should be made for the installation of AV equipment in laboratories so that it is clear of any hazards, including electrical hazard that may be caused by spills or ingress of fumes or residue from chemicals.

All equipment installed should conform to the specifications set out in Section 27. Approval for equipment types should be referred to JCU Videoconferencing and Audio Visual Services (VAVS). Screen sizes and sightlines must conform to appropriate standards including the AETM Audio Visual Design Guidelines as set out in section 27.

For multi-use teaching laboratories consideration should be given to thdld Vi (r8(s)-9.3(e)-11(c)0.9(t83.7(u)-5

37.14 Health & Safety Provisions

Refer to AS/NZS 2982.1 for typical safety provisions for laboratories. These may include hand washing facilities, safety showers and eye wash, safety and evacuation signage, noticeboards, chemical storage placarding and storage of safety equipment and data records such as MSDS.

37.14.1 Signage

Provide all statutory and safety signage as per relevant legislation and codes and standards. This signage is to be included in the construction budget.

37.14.2 Rad

15.4(S-3.36 Tc)12.9(s)oeaf8pTf -0.0072d [(37.)(fw /H3 Tc -0.l0 Tc 0 Tw B)6.6(e)9T

Providing benches which are flexible and adjustable in height enables a variety of users access to the working surface to suit their particular need. An average of o

- Laboratories dealing with and containing AQIS materials are categorised as either QC1, QC2, QC3 or QC4 facilities.
- NMR facilities (Nuclear magnetic resonance)
- Electron microscopy

37.16.1 Potential issues

- Vision panels with ‘black out’ flaps
- Rodent barriers
- Doors to the outer perimeter of the facility must be access controlled
-